



Punjab Fire Services (Mansa)



FIRE SAFETY CERTIFICATE ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No 311-112140-Fire/86192
Apr-2025

NOC Type: **Renew**

Dated **16-**

Certified that the **Alpine Public School Mansa** at **Sirsa Barnala Raod Mansa** comprised of **0** basements and **2** (Upper floor) owned/occupied by **PAWAN KUMAR** have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **11-Apr-2025** in the presence of **PAWAN KUMAR** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **B** subdivision **B1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **16-Apr-2025** at **Mansa**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **Alpine Public School Mansa** ਜੋ ਕਿ **Sirsa Barnala Raod Mansa** ਸਮੇਤ **0** ਬੇਸਮੈਂਟ ਅਤੇ **2** (ਉੱਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **PAWAN KUMAR** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਊ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **11-Apr-2025** ਮੌਜੂਦਗੀ ਵਿੱਚ **PAWAN KUMAR** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group **B** subdivision **B1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ ਇੱਕ ਸਾਲ ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **16-Apr-2025** ਕਿੱਥੇ **Mansa** .

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ / ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.
ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂੰ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।
4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
ਫਾਇਰ ਬ੍ਰਿਗੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।
5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.
ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

* Above Details cannot be used as ownership proof.

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitally created certificate, no signature are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਾਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

Inspection Report by Fire Officer

PERFORMA FOR INSPECTION REPORT REGARDING**PREVENTION OF FIRE AND SAFETY MEASURES**

(High rise/multi-storey buildings, hospitals, nursing homes, corporate offices, factories and hazardous storage)

Date of Inspection :- 11-04-2025

Sr. No.	Details / Checkpoints	Details of the Building / premises / fire safety measures
1	Name of the building / premises (Location / Address)	Alpine Public School, Sirsa Barnala Raod, Mansa
2	Name & Address of the owner with contact no. (s)	PAWAN KUMAR contact no : 9815828281 Address : DHOBI GHATT STREET, WARD NO.18, MANSA
3	Name & Address of the Occupier (s) with contact no. (s)	PAWAN KUMAR contact no : 9815828281 Address : DHOBI GHATT STREET, WARD NO.18, MANSA
4	Total area of the premises (m2)	8431
5	Total Covered area (m2)	2660
6	Height of the building from ground level (Mtrs.)	8m
7	Number of basements & its area	NIL
8	Number of sanctioned floors	2
9	Number of actual floors	2
10	Parking area (m2)	Inside Building
11	Details of surrounding properties a) Front Side b) Left Side c) Right Side d) Back side	As per online application submitted
12	Number of Main Gates with size	1
13	Number of fire extinguishers installed in the building on each floor with capacity, type with ISI Marking number and date of manufacturing	ABC-10 Capacity 4kg ISI Mark CO2-1 Capacity 4.5kg ISI Mark
14	Detail of Hose reel on each floor indicating size and length of rubber pipe	NR
15	Details of wet rises, No. of Landing valve, delivery hose, pipe and hose cabinet on each floor	NR
16	No. of yard hydrant, with detail	NR
17	Whether basement is being used for parking, storage or office. Has the basement sprinkler system? Give all details	NR
18	No. of manual fire alarm installed in the building	Yes- 1
19	Details of automatic fire detection system P.A system provided in the building	PA system available
20	Details of Control Panels	NR
21	Details of Water storage capacity underground / overhead with size of tank	3000L

22	Detail of fire pumps with head and make a) Main Pump b) Jockey Pump c) Diesel Pump	NR
23	Position of fire service Inlet (2way,3 way, 4way)	NR
24	No. of stair cases with size	2
25	No. of lifts and ramps with details of communication system	NR
26	Details of mean of escape	Doors and staircase
27	Stand by source of power supply with all details of Gen set and location of switch details	Gen Set Available(Three phase supply)
28	Is building centrally air conditioned? Give details	NO
29	Have all exits and directions of travel in each been sign posted?	Yes
30	Do the fire safety measures confirm to the norms of NBC ?	Yes
31	Details of Previous NOC (In renewal cases) (1) Name of the issuing authority (2) Date up to which it is valid.	Renew
Recommendation of Inspection Officer		
1. Install Fire Hose reel system. 2. Conduct periodic Drill and Fire Training.		
Signature : Harinderpal Singh		
Name of Inspecting officer:- Harinderpal Singh		
Designation :- Assistant Divisional Fire Officer		